

**HYDRO PRESSURE TEST**

TC No.: HPT/MOD5/CA/FK/RQ/026/25

Model No.: KMCRQ-5-FK

Date: 12-04-2025

Type and Capacity of Extinguisher : KMCRQ-5-FK-Kanex Clean Agent FK5112 Based Fire Extinguisher Cap. 5 Kg.

Batch Number : KMCRQ5FK 026/25

Batch Quantity : 10.00 Nos.

Serial Numbers : 00251 To 260

Month of Manufacturing : Apr/25

Sr. Nos.

Result

Sr. Nos.

Result

Sr. Nos.

Result

Sr. Nos.

Result

Burst test conducted on 00251 To 260 and removed from the Lot/Batch

|     |      |     |      |     |      |     |      |
|-----|------|-----|------|-----|------|-----|------|
| 251 | Pass | 252 | Pass | 253 | Pass | 254 | Pass |
| 255 | Pass | 256 | Pass | 257 | Pass | 258 | Pass |
| 259 | Pass | 260 | Pass |     |      |     |      |

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**