

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/FK/RQ/027/25	Model No.: KMCRQ-5-FK	Date: 17-04-2025
Type and Capacity of Extinguisher	: KMCRQ-5-FK-Kanex Clean Agent FK5112 Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5FK 027/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00261 To 270	
Month of Manufacturing	: Apr/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00261 To 270 and removed from the Lot/Batch							
261	Pass	262	Pass	263	Pass	264	Pass
265	Pass	266	Pass	267	Pass	268	Pass
269	Pass	270	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory