

HYDRO PRESSURE TEST

TC No.: HPT/CA4/RQ/033/25	Model No.: KCARQ-4	Date: 02-12-2025
Type and Capacity of Extinguisher	: KCARQ-4-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KCARQ4 033/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 03201 To 3300 And 3205A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 3205A and removed from the Lot/Batch							
3201	Pass	3202	Pass	3203	Pass	3204	Pass
3205	Pass	3206	Pass	3207	Pass	3208	Pass
3209	Pass	3210	Pass	3211	Pass	3212	Pass
3213	Pass	3214	Pass	3215	Pass	3216	Pass
3217	Pass	3218	Pass	3219	Pass	3220	Pass
3221	Pass	3222	Pass	3223	Pass	3224	Pass
3225	Pass	3226	Pass	3227	Pass	3228	Pass
3229	Pass	3230	Pass	3231	Pass	3232	Pass
3233	Pass	3234	Pass	3235	Pass	3236	Pass
3237	Pass	3238	Pass	3239	Pass	3240	Pass
3241	Pass	3242	Pass	3243	Pass	3244	Pass
3245	Pass	3246	Pass	3247	Pass	3248	Pass
3249	Pass	3250	Pass	3251	Pass	3252	Pass
3253	Pass	3254	Pass	3255	Pass	3256	Pass
3257	Pass	3258	Pass	3259	Pass	3260	Pass
3261	Pass	3262	Pass	3263	Pass	3264	Pass
3265	Pass	3266	Pass	3267	Pass	3268	Pass
3269	Pass	3270	Pass	3271	Pass	3272	Pass
3273	Pass	3274	Pass	3275	Pass	3276	Pass
3277	Pass	3278	Pass	3279	Pass	3280	Pass
3281	Pass	3282	Pass	3283	Pass	3284	Pass
3285	Pass	3286	Pass	3287	Pass	3288	Pass
3289	Pass	3290	Pass	3291	Pass	3292	Pass
3293	Pass	3294	Pass	3295	Pass	3296	Pass
3297	Pass	3298	Pass	3299	Pass	3300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory