



Lumezzane (BS) Italy, 10/04/2024

SUBJECT: Declaration

Camozzi SpA declares that the Push Fittings series 8000 are in accordance with the requirements of ISO 14743-2004 "Push-in connectors for tubes".

Customer Name: Kanex Fire Solutions Limited - India

P.O.: 11886 DT. 26-02-2024

TEST CERTIFICATE

Camozzi Code	Qty.	Testing Pressure	Result
8512 6-1/8	900 Nos.	-0.9 ÷ 60 bar	Passed
8512 6-1/8 +2613-1/8	400 Nos.	-0.9 ÷ 60 bar	Passed

**Technical
department
Gianluca Gnutti**

**Quality
department
Mauro Berna**

Gianluca Gnutti
Mauro Berna