



Warranty Certificate

Date: 10-02-2026

Manufacturer: Kanex Fire Solutions Limited.

Customer Name: S.D. Sales CorporationWarranty Start Date: 10-02-2026Warranty End Date: 09-02-2027.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	43	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/N/000631 Dated: 10-02-2026 P.O.No. 2025-2026/196** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.



Authorized Signatory

