

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/083/25	Model No.: KFARQ-4-50%	Date: 10-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 083/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 08201 To 8300 And 8205A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 8205A and removed from the Lot/Batch							
8201	Pass	8202	Pass	8203	Pass	8204	Pass
8205	Pass	8206	Pass	8207	Pass	8208	Pass
8209	Pass	8210	Pass	8211	Pass	8212	Pass
8213	Pass	8214	Pass	8215	Pass	8216	Pass
8217	Pass	8218	Pass	8219	Pass	8220	Pass
8221	Pass	8222	Pass	8223	Pass	8224	Pass
8225	Pass	8226	Pass	8227	Pass	8228	Pass
8229	Pass	8230	Pass	8231	Pass	8232	Pass
8233	Pass	8234	Pass	8235	Pass	8236	Pass
8237	Pass	8238	Pass	8239	Pass	8240	Pass
8241	Pass	8242	Pass	8243	Pass	8244	Pass
8245	Pass	8246	Pass	8247	Pass	8248	Pass
8249	Pass	8250	Pass	8251	Pass	8252	Pass
8253	Pass	8254	Pass	8255	Pass	8256	Pass
8257	Pass	8258	Pass	8259	Pass	8260	Pass
8261	Pass	8262	Pass	8263	Pass	8264	Pass
8265	Pass	8266	Pass	8267	Pass	8268	Pass
8269	Pass	8270	Pass	8271	Pass	8272	Pass
8273	Pass	8274	Pass	8275	Pass	8276	Pass
8277	Pass	8278	Pass	8279	Pass	8280	Pass
8281	Pass	8282	Pass	8283	Pass	8284	Pass
8285	Pass	8286	Pass	8287	Pass	8288	Pass
8289	Pass	8290	Pass	8291	Pass	8292	Pass
8293	Pass	8294	Pass	8295	Pass	8296	Pass
8297	Pass	8298	Pass	8299	Pass	8300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory