

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/A90/RQ/003/26	Model No.: KMPRQ-5-90%	Date: 24-01-2026
Type and Capacity of Extinguisher	: KMPRQ-5-90%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMPRQ90%5 003/26	
Batch Quantity	: 100.00 Nos.	
Serial Numbers	: 00201 To 300	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00201 To 300 and removed from the Lot/Batch							
201	Pass	202	Pass	203	Pass	204	Pass
205	Pass	206	Pass	207	Pass	208	Pass
209	Pass	210	Pass	211	Pass	212	Pass
213	Pass	214	Pass	215	Pass	216	Pass
217	Pass	218	Pass	219	Pass	220	Pass
221	Pass	222	Pass	223	Pass	224	Pass
225	Pass	226	Pass	227	Pass	228	Pass
229	Pass	230	Pass	231	Pass	232	Pass
233	Pass	234	Pass	235	Pass	236	Pass
237	Pass	238	Pass	239	Pass	240	Pass
241	Pass	242	Pass	243	Pass	244	Pass
245	Pass	246	Pass	247	Pass	248	Pass
249	Pass	250	Pass	251	Pass	252	Pass
253	Pass	254	Pass	255	Pass	256	Pass
257	Pass	258	Pass	259	Pass	260	Pass
261	Pass	262	Pass	263	Pass	264	Pass
265	Pass	266	Pass	267	Pass	268	Pass
269	Pass	270	Pass	271	Pass	272	Pass
273	Pass	274	Pass	275	Pass	276	Pass
277	Pass	278	Pass	279	Pass	280	Pass
281	Pass	282	Pass	283	Pass	284	Pass
285	Pass	286	Pass	287	Pass	288	Pass
289	Pass	290	Pass	291	Pass	292	Pass
293	Pass	294	Pass	295	Pass	296	Pass
297	Pass	298	Pass	299	Pass	300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory