

# HYDRO PRESSURE TEST

|                                   |                                                          |                  |
|-----------------------------------|----------------------------------------------------------|------------------|
| TC No.: HPT/F9/SP/RQ/008/26       | Model No.: KFMSRQ-9                                      | Date: 24-01-2026 |
| Type and Capacity of Extinguisher | : KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr. |                  |
| Batch Number                      | : KFMSRQ9 008/26                                         |                  |
| Batch Quantity                    | : 101.00 Nos.                                            |                  |
| Serial Numbers                    | : 00701 To 800 And 705A                                  |                  |
| Month of Manufacturing            | : Jan/26                                                 |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 705A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 701                                                         | Pass   | 702      | Pass   | 703      | Pass   | 704      | Pass   |
| 705                                                         | Pass   | 706      | Pass   | 707      | Pass   | 708      | Pass   |
| 709                                                         | Pass   | 710      | Pass   | 711      | Pass   | 712      | Pass   |
| 713                                                         | Pass   | 714      | Pass   | 715      | Pass   | 716      | Pass   |
| 717                                                         | Pass   | 718      | Pass   | 719      | Pass   | 720      | Pass   |
| 721                                                         | Pass   | 722      | Pass   | 723      | Pass   | 724      | Pass   |
| 725                                                         | Pass   | 726      | Pass   | 727      | Pass   | 728      | Pass   |
| 729                                                         | Pass   | 730      | Pass   | 731      | Pass   | 732      | Pass   |
| 733                                                         | Pass   | 734      | Pass   | 735      | Pass   | 736      | Pass   |
| 737                                                         | Pass   | 738      | Pass   | 739      | Pass   | 740      | Pass   |
| 741                                                         | Pass   | 742      | Pass   | 743      | Pass   | 744      | Pass   |
| 745                                                         | Pass   | 746      | Pass   | 747      | Pass   | 748      | Pass   |
| 749                                                         | Pass   | 750      | Pass   | 751      | Pass   | 752      | Pass   |
| 753                                                         | Pass   | 754      | Pass   | 755      | Pass   | 756      | Pass   |
| 757                                                         | Pass   | 758      | Pass   | 759      | Pass   | 760      | Pass   |
| 761                                                         | Pass   | 762      | Pass   | 763      | Pass   | 764      | Pass   |
| 765                                                         | Pass   | 766      | Pass   | 767      | Pass   | 768      | Pass   |
| 769                                                         | Pass   | 770      | Pass   | 771      | Pass   | 772      | Pass   |
| 773                                                         | Pass   | 774      | Pass   | 775      | Pass   | 776      | Pass   |
| 777                                                         | Pass   | 778      | Pass   | 779      | Pass   | 780      | Pass   |
| 781                                                         | Pass   | 782      | Pass   | 783      | Pass   | 784      | Pass   |
| 785                                                         | Pass   | 786      | Pass   | 787      | Pass   | 788      | Pass   |
| 789                                                         | Pass   | 790      | Pass   | 791      | Pass   | 792      | Pass   |
| 793                                                         | Pass   | 794      | Pass   | 795      | Pass   | 796      | Pass   |
| 797                                                         | Pass   | 798      | Pass   | 799      | Pass   | 800      | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**