

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/011/26	Model No.: KFKHQ-6	Date: 24-01-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 011/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00101 To 110 And 105A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 105A and removed from the Lot/Batch							
101	Pass	102	Pass	103	Pass	104	Pass
105	Pass	106	Pass	107	Pass	108	Pass
109	Pass	110	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory