

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/022/26	Model No.: KFKHQ-6	Date: 10-02-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 022/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00211 To 220 And 215A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 215A and removed from the Lot/Batch							
211	Pass	212	Pass	213	Pass	214	Pass
215	Pass	216	Pass	217	Pass	218	Pass
219	Pass	220	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory