

HYDRO PRESSURE TEST

TC No.: HPT/CA2/RQ/027/25	Model No.: KCARQ-2	Date: 08-09-2025
Type and Capacity of Extinguisher	: KCARQ-2-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KCARQ2 027/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 02601 To 2700 And 2605A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 2605A and removed from the Lot/Batch							
2601	Pass	2602	Pass	2603	Pass	2604	Pass
2605	Pass	2606	Pass	2607	Pass	2608	Pass
2609	Pass	2610	Pass	2611	Pass	2612	Pass
2613	Pass	2614	Pass	2615	Pass	2616	Pass
2617	Pass	2618	Pass	2619	Pass	2620	Pass
2621	Pass	2622	Pass	2623	Pass	2624	Pass
2625	Pass	2626	Pass	2627	Pass	2628	Pass
2629	Pass	2630	Pass	2631	Pass	2632	Pass
2633	Pass	2634	Pass	2635	Pass	2636	Pass
2637	Pass	2638	Pass	2639	Pass	2640	Pass
2641	Pass	2642	Pass	2643	Pass	2644	Pass
2645	Pass	2646	Pass	2647	Pass	2648	Pass
2649	Pass	2650	Pass	2651	Pass	2652	Pass
2653	Pass	2654	Pass	2655	Pass	2656	Pass
2657	Pass	2658	Pass	2659	Pass	2660	Pass
2661	Pass	2662	Pass	2663	Pass	2664	Pass
2665	Pass	2666	Pass	2667	Pass	2668	Pass
2669	Pass	2670	Pass	2671	Pass	2672	Pass
2673	Pass	2674	Pass	2675	Pass	2676	Pass
2677	Pass	2678	Pass	2679	Pass	2680	Pass
2681	Pass	2682	Pass	2683	Pass	2684	Pass
2685	Pass	2686	Pass	2687	Pass	2688	Pass
2689	Pass	2690	Pass	2691	Pass	2692	Pass
2693	Pass	2694	Pass	2695	Pass	2696	Pass
2697	Pass	2698	Pass	2699	Pass	2700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory