

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/057/26	Model No.: KFARQ-4-90%	Date: 17-02-2026
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 057/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 05601 To 5700 And 5605A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5605A and removed from the Lot/Batch							
5601	Pass	5602	Pass	5603	Pass	5604	Pass
5605	Pass	5606	Pass	5607	Pass	5608	Pass
5609	Pass	5610	Pass	5611	Pass	5612	Pass
5613	Pass	5614	Pass	5615	Pass	5616	Pass
5617	Pass	5618	Pass	5619	Pass	5620	Pass
5621	Pass	5622	Pass	5623	Pass	5624	Pass
5625	Pass	5626	Pass	5627	Pass	5628	Pass
5629	Pass	5630	Pass	5631	Pass	5632	Pass
5633	Pass	5634	Pass	5635	Pass	5636	Pass
5637	Pass	5638	Pass	5639	Pass	5640	Pass
5641	Pass	5642	Pass	5643	Pass	5644	Pass
5645	Pass	5646	Pass	5647	Pass	5648	Pass
5649	Pass	5650	Pass	5651	Pass	5652	Pass
5653	Pass	5654	Pass	5655	Pass	5656	Pass
5657	Pass	5658	Pass	5659	Pass	5660	Pass
5661	Pass	5662	Pass	5663	Pass	5664	Pass
5665	Pass	5666	Pass	5667	Pass	5668	Pass
5669	Pass	5670	Pass	5671	Pass	5672	Pass
5673	Pass	5674	Pass	5675	Pass	5676	Pass
5677	Pass	5678	Pass	5679	Pass	5680	Pass
5681	Pass	5682	Pass	5683	Pass	5684	Pass
5685	Pass	5686	Pass	5687	Pass	5688	Pass
5689	Pass	5690	Pass	5691	Pass	5692	Pass
5693	Pass	5694	Pass	5695	Pass	5696	Pass
5697	Pass	5698	Pass	5699	Pass	5700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory