

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/064/26	Model No.: KFARQ-6-90%	Date: 07-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 064/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 06301 To 6400 And 6305A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 6305A and removed from the Lot/Batch							
6301	Pass	6302	Pass	6303	Pass	6304	Pass
6305	Pass	6306	Pass	6307	Pass	6308	Pass
6309	Pass	6310	Pass	6311	Pass	6312	Pass
6313	Pass	6314	Pass	6315	Pass	6316	Pass
6317	Pass	6318	Pass	6319	Pass	6320	Pass
6321	Pass	6322	Pass	6323	Pass	6324	Pass
6325	Pass	6326	Pass	6327	Pass	6328	Pass
6329	Pass	6330	Pass	6331	Pass	6332	Pass
6333	Pass	6334	Pass	6335	Pass	6336	Pass
6337	Pass	6338	Pass	6339	Pass	6340	Pass
6341	Pass	6342	Pass	6343	Pass	6344	Pass
6345	Pass	6346	Pass	6347	Pass	6348	Pass
6349	Pass	6350	Pass	6351	Pass	6352	Pass
6353	Pass	6354	Pass	6355	Pass	6356	Pass
6357	Pass	6358	Pass	6359	Pass	6360	Pass
6361	Pass	6362	Pass	6363	Pass	6364	Pass
6365	Pass	6366	Pass	6367	Pass	6368	Pass
6369	Pass	6370	Pass	6371	Pass	6372	Pass
6373	Pass	6374	Pass	6375	Pass	6376	Pass
6377	Pass	6378	Pass	6379	Pass	6380	Pass
6381	Pass	6382	Pass	6383	Pass	6384	Pass
6385	Pass	6386	Pass	6387	Pass	6388	Pass
6389	Pass	6390	Pass	6391	Pass	6392	Pass
6393	Pass	6394	Pass	6395	Pass	6396	Pass
6397	Pass	6398	Pass	6399	Pass	6400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory