

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/124/25	Model No.: KMCRQ-10	Date: 08-09-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 124/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01231 To 1240	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01231 To 1240 and removed from the Lot/Batch							
1231	Pass	1232	Pass	1233	Pass	1234	Pass
1235	Pass	1236	Pass	1237	Pass	1238	Pass
1239	Pass	1240	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory