

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/078/25	Model No.: KFARQ-2-90%	Date: 14-08-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 078/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 07701 To 7800 And 7705A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 7705A and removed from the Lot/Batch							
7701	Pass	7702	Pass	7703	Pass	7704	Pass
7705	Pass	7706	Pass	7707	Pass	7708	Pass
7709	Pass	7710	Pass	7711	Pass	7712	Pass
7713	Pass	7714	Pass	7715	Pass	7716	Pass
7717	Pass	7718	Pass	7719	Pass	7720	Pass
7721	Pass	7722	Pass	7723	Pass	7724	Pass
7725	Pass	7726	Pass	7727	Pass	7728	Pass
7729	Pass	7730	Pass	7731	Pass	7732	Pass
7733	Pass	7734	Pass	7735	Pass	7736	Pass
7737	Pass	7738	Pass	7739	Pass	7740	Pass
7741	Pass	7742	Pass	7743	Pass	7744	Pass
7745	Pass	7746	Pass	7747	Pass	7748	Pass
7749	Pass	7750	Pass	7751	Pass	7752	Pass
7753	Pass	7754	Pass	7755	Pass	7756	Pass
7757	Pass	7758	Pass	7759	Pass	7760	Pass
7761	Pass	7762	Pass	7763	Pass	7764	Pass
7765	Pass	7766	Pass	7767	Pass	7768	Pass
7769	Pass	7770	Pass	7771	Pass	7772	Pass
7773	Pass	7774	Pass	7775	Pass	7776	Pass
7777	Pass	7778	Pass	7779	Pass	7780	Pass
7781	Pass	7782	Pass	7783	Pass	7784	Pass
7785	Pass	7786	Pass	7787	Pass	7788	Pass
7789	Pass	7790	Pass	7791	Pass	7792	Pass
7793	Pass	7794	Pass	7795	Pass	7796	Pass
7797	Pass	7798	Pass	7799	Pass	7800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory