

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/187/25	Model No.: KFARQ-4-90%	Date: 06-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 187/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 18601 To 18700 And 18605A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 18605A and removed from the Lot/Batch							
18601	Pass	18602	Pass	18603	Pass	18604	Pass
18605	Pass	18606	Pass	18607	Pass	18608	Pass
18609	Pass	18610	Pass	18611	Pass	18612	Pass
18613	Pass	18614	Pass	18615	Pass	18616	Pass
18617	Pass	18618	Pass	18619	Pass	18620	Pass
18621	Pass	18622	Pass	18623	Pass	18624	Pass
18625	Pass	18626	Pass	18627	Pass	18628	Pass
18629	Pass	18630	Pass	18631	Pass	18632	Pass
18633	Pass	18634	Pass	18635	Pass	18636	Pass
18637	Pass	18638	Pass	18639	Pass	18640	Pass
18641	Pass	18642	Pass	18643	Pass	18644	Pass
18645	Pass	18646	Pass	18647	Pass	18648	Pass
18649	Pass	18650	Pass	18651	Pass	18652	Pass
18653	Pass	18654	Pass	18655	Pass	18656	Pass
18657	Pass	18658	Pass	18659	Pass	18660	Pass
18661	Pass	18662	Pass	18663	Pass	18664	Pass
18665	Pass	18666	Pass	18667	Pass	18668	Pass
18669	Pass	18670	Pass	18671	Pass	18672	Pass
18673	Pass	18674	Pass	18675	Pass	18676	Pass
18677	Pass	18678	Pass	18679	Pass	18680	Pass
18681	Pass	18682	Pass	18683	Pass	18684	Pass
18685	Pass	18686	Pass	18687	Pass	18688	Pass
18689	Pass	18690	Pass	18691	Pass	18692	Pass
18693	Pass	18694	Pass	18695	Pass	18696	Pass
18697	Pass	18698	Pass	18699	Pass	18700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory