

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/109/25	Model No.: KMCRQ-10	Date: 25-08-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 109/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01081 To 1090	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01081 To 1090 and removed from the Lot/Batch							
1081	Pass	1082	Pass	1083	Pass	1084	Pass
1085	Pass	1086	Pass	1087	Pass	1088	Pass
1089	Pass	1090	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory