

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/108/25	Model No.: KMCRQ-10	Date: 25-08-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 108/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01071 To 1080	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01071 To 1080 and removed from the Lot/Batch							
1071	Pass	1072	Pass	1073	Pass	1074	Pass
1075	Pass	1076	Pass	1077	Pass	1078	Pass
1079	Pass	1080	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory