

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/075/25	Model No.: KFARQ-2-90%	Date: 12-07-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 075/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 07401 To 7500 And 7405A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 7405A and removed from the Lot/Batch							
7401	Pass	7402	Pass	7403	Pass	7404	Pass
7405	Pass	7406	Pass	7407	Pass	7408	Pass
7409	Pass	7410	Pass	7411	Pass	7412	Pass
7413	Pass	7414	Pass	7415	Pass	7416	Pass
7417	Pass	7418	Pass	7419	Pass	7420	Pass
7421	Pass	7422	Pass	7423	Pass	7424	Pass
7425	Pass	7426	Pass	7427	Pass	7428	Pass
7429	Pass	7430	Pass	7431	Pass	7432	Pass
7433	Pass	7434	Pass	7435	Pass	7436	Pass
7437	Pass	7438	Pass	7439	Pass	7440	Pass
7441	Pass	7442	Pass	7443	Pass	7444	Pass
7445	Pass	7446	Pass	7447	Pass	7448	Pass
7449	Pass	7450	Pass	7451	Pass	7452	Pass
7453	Pass	7454	Pass	7455	Pass	7456	Pass
7457	Pass	7458	Pass	7459	Pass	7460	Pass
7461	Pass	7462	Pass	7463	Pass	7464	Pass
7465	Pass	7466	Pass	7467	Pass	7468	Pass
7469	Pass	7470	Pass	7471	Pass	7472	Pass
7473	Pass	7474	Pass	7475	Pass	7476	Pass
7477	Pass	7478	Pass	7479	Pass	7480	Pass
7481	Pass	7482	Pass	7483	Pass	7484	Pass
7485	Pass	7486	Pass	7487	Pass	7488	Pass
7489	Pass	7490	Pass	7491	Pass	7492	Pass
7493	Pass	7494	Pass	7495	Pass	7496	Pass
7497	Pass	7498	Pass	7499	Pass	7500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory