

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/275/25	Model No.: KFARQ-6-50%	Date: 22-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 275/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 27401 To 27500 And 27405A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 27405A and removed from the Lot/Batch							
27401	Pass	27402	Pass	27403	Pass	27404	Pass
27405	Pass	27406	Pass	27407	Pass	27408	Pass
27409	Pass	27410	Pass	27411	Pass	27412	Pass
27413	Pass	27414	Pass	27415	Pass	27416	Pass
27417	Pass	27418	Pass	27419	Pass	27420	Pass
27421	Pass	27422	Pass	27423	Pass	27424	Pass
27425	Pass	27426	Pass	27427	Pass	27428	Pass
27429	Pass	27430	Pass	27431	Pass	27432	Pass
27433	Pass	27434	Pass	27435	Pass	27436	Pass
27437	Pass	27438	Pass	27439	Pass	27440	Pass
27441	Pass	27442	Pass	27443	Pass	27444	Pass
27445	Pass	27446	Pass	27447	Pass	27448	Pass
27449	Pass	27450	Pass	27451	Pass	27452	Pass
27453	Pass	27454	Pass	27455	Pass	27456	Pass
27457	Pass	27458	Pass	27459	Pass	27460	Pass
27461	Pass	27462	Pass	27463	Pass	27464	Pass
27465	Pass	27466	Pass	27467	Pass	27468	Pass
27469	Pass	27470	Pass	27471	Pass	27472	Pass
27473	Pass	27474	Pass	27475	Pass	27476	Pass
27477	Pass	27478	Pass	27479	Pass	27480	Pass
27481	Pass	27482	Pass	27483	Pass	27484	Pass
27485	Pass	27486	Pass	27487	Pass	27488	Pass
27489	Pass	27490	Pass	27491	Pass	27492	Pass
27493	Pass	27494	Pass	27495	Pass	27496	Pass
27497	Pass	27498	Pass	27499	Pass	27500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory