

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/085/25	Model No.: KFARQ-2-90%	Date: 04-09-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 085/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 08401 To 8500 And 8405A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 8405A and removed from the Lot/Batch							
8401	Pass	8402	Pass	8403	Pass	8404	Pass
8405	Pass	8406	Pass	8407	Pass	8408	Pass
8409	Pass	8410	Pass	8411	Pass	8412	Pass
8413	Pass	8414	Pass	8415	Pass	8416	Pass
8417	Pass	8418	Pass	8419	Pass	8420	Pass
8421	Pass	8422	Pass	8423	Pass	8424	Pass
8425	Pass	8426	Pass	8427	Pass	8428	Pass
8429	Pass	8430	Pass	8431	Pass	8432	Pass
8433	Pass	8434	Pass	8435	Pass	8436	Pass
8437	Pass	8438	Pass	8439	Pass	8440	Pass
8441	Pass	8442	Pass	8443	Pass	8444	Pass
8445	Pass	8446	Pass	8447	Pass	8448	Pass
8449	Pass	8450	Pass	8451	Pass	8452	Pass
8453	Pass	8454	Pass	8455	Pass	8456	Pass
8457	Pass	8458	Pass	8459	Pass	8460	Pass
8461	Pass	8462	Pass	8463	Pass	8464	Pass
8465	Pass	8466	Pass	8467	Pass	8468	Pass
8469	Pass	8470	Pass	8471	Pass	8472	Pass
8473	Pass	8474	Pass	8475	Pass	8476	Pass
8477	Pass	8478	Pass	8479	Pass	8480	Pass
8481	Pass	8482	Pass	8483	Pass	8484	Pass
8485	Pass	8486	Pass	8487	Pass	8488	Pass
8489	Pass	8490	Pass	8491	Pass	8492	Pass
8493	Pass	8494	Pass	8495	Pass	8496	Pass
8497	Pass	8498	Pass	8499	Pass	8500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory