

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/074/25	Model No.: KFARQ-4-50%	Date: 25-09-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 074/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 07301 To 7400 And 7305A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 7305A and removed from the Lot/Batch							
7301	Pass	7302	Pass	7303	Pass	7304	Pass
7305	Pass	7306	Pass	7307	Pass	7308	Pass
7309	Pass	7310	Pass	7311	Pass	7312	Pass
7313	Pass	7314	Pass	7315	Pass	7316	Pass
7317	Pass	7318	Pass	7319	Pass	7320	Pass
7321	Pass	7322	Pass	7323	Pass	7324	Pass
7325	Pass	7326	Pass	7327	Pass	7328	Pass
7329	Pass	7330	Pass	7331	Pass	7332	Pass
7333	Pass	7334	Pass	7335	Pass	7336	Pass
7337	Pass	7338	Pass	7339	Pass	7340	Pass
7341	Pass	7342	Pass	7343	Pass	7344	Pass
7345	Pass	7346	Pass	7347	Pass	7348	Pass
7349	Pass	7350	Pass	7351	Pass	7352	Pass
7353	Pass	7354	Pass	7355	Pass	7356	Pass
7357	Pass	7358	Pass	7359	Pass	7360	Pass
7361	Pass	7362	Pass	7363	Pass	7364	Pass
7365	Pass	7366	Pass	7367	Pass	7368	Pass
7369	Pass	7370	Pass	7371	Pass	7372	Pass
7373	Pass	7374	Pass	7375	Pass	7376	Pass
7377	Pass	7378	Pass	7379	Pass	7380	Pass
7381	Pass	7382	Pass	7383	Pass	7384	Pass
7385	Pass	7386	Pass	7387	Pass	7388	Pass
7389	Pass	7390	Pass	7391	Pass	7392	Pass
7393	Pass	7394	Pass	7395	Pass	7396	Pass
7397	Pass	7398	Pass	7399	Pass	7400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory