

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/054/25	Model No.: KFARQ-4-50%	Date: 12-07-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 054/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 05301 To 5400 And 5305A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5305A and removed from the Lot/Batch							
5301	Pass	5302	Pass	5303	Pass	5304	Pass
5305	Pass	5306	Pass	5307	Pass	5308	Pass
5309	Pass	5310	Pass	5311	Pass	5312	Pass
5313	Pass	5314	Pass	5315	Pass	5316	Pass
5317	Pass	5318	Pass	5319	Pass	5320	Pass
5321	Pass	5322	Pass	5323	Pass	5324	Pass
5325	Pass	5326	Pass	5327	Pass	5328	Pass
5329	Pass	5330	Pass	5331	Pass	5332	Pass
5333	Pass	5334	Pass	5335	Pass	5336	Pass
5337	Pass	5338	Pass	5339	Pass	5340	Pass
5341	Pass	5342	Pass	5343	Pass	5344	Pass
5345	Pass	5346	Pass	5347	Pass	5348	Pass
5349	Pass	5350	Pass	5351	Pass	5352	Pass
5353	Pass	5354	Pass	5355	Pass	5356	Pass
5357	Pass	5358	Pass	5359	Pass	5360	Pass
5361	Pass	5362	Pass	5363	Pass	5364	Pass
5365	Pass	5366	Pass	5367	Pass	5368	Pass
5369	Pass	5370	Pass	5371	Pass	5372	Pass
5373	Pass	5374	Pass	5375	Pass	5376	Pass
5377	Pass	5378	Pass	5379	Pass	5380	Pass
5381	Pass	5382	Pass	5383	Pass	5384	Pass
5385	Pass	5386	Pass	5387	Pass	5388	Pass
5389	Pass	5390	Pass	5391	Pass	5392	Pass
5393	Pass	5394	Pass	5395	Pass	5396	Pass
5397	Pass	5398	Pass	5399	Pass	5400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory