

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/128/25	Model No.: KFARQ-6-50%	Date: 05-04-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 128/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 12701 To 12800 And 12705A	
Month of Manufacturing	: Apr/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 12705A and removed from the Lot/Batch							
12701	Pass	12702	Pass	12703	Pass	12704	Pass
12705	Pass	12706	Pass	12707	Pass	12708	Pass
12709	Pass	12710	Pass	12711	Pass	12712	Pass
12713	Pass	12714	Pass	12715	Pass	12716	Pass
12717	Pass	12718	Pass	12719	Pass	12720	Pass
12721	Pass	12722	Pass	12723	Pass	12724	Pass
12725	Pass	12726	Pass	12727	Pass	12728	Pass
12729	Pass	12730	Pass	12731	Pass	12732	Pass
12733	Pass	12734	Pass	12735	Pass	12736	Pass
12737	Pass	12738	Pass	12739	Pass	12740	Pass
12741	Pass	12742	Pass	12743	Pass	12744	Pass
12745	Pass	12746	Pass	12747	Pass	12748	Pass
12749	Pass	12750	Pass	12751	Pass	12752	Pass
12753	Pass	12754	Pass	12755	Pass	12756	Pass
12757	Pass	12758	Pass	12759	Pass	12760	Pass
12761	Pass	12762	Pass	12763	Pass	12764	Pass
12765	Pass	12766	Pass	12767	Pass	12768	Pass
12769	Pass	12770	Pass	12771	Pass	12772	Pass
12773	Pass	12774	Pass	12775	Pass	12776	Pass
12777	Pass	12778	Pass	12779	Pass	12780	Pass
12781	Pass	12782	Pass	12783	Pass	12784	Pass
12785	Pass	12786	Pass	12787	Pass	12788	Pass
12789	Pass	12790	Pass	12791	Pass	12792	Pass
12793	Pass	12794	Pass	12795	Pass	12796	Pass
12797	Pass	12798	Pass	12799	Pass	12800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory