

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/335/25	Model No.: KFARQ-6-50%	Date: 25-11-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 335/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 33401 To 33500 And 33405A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 33405A and removed from the Lot/Batch							
33401	Pass	33402	Pass	33403	Pass	33404	Pass
33405	Pass	33406	Pass	33407	Pass	33408	Pass
33409	Pass	33410	Pass	33411	Pass	33412	Pass
33413	Pass	33414	Pass	33415	Pass	33416	Pass
33417	Pass	33418	Pass	33419	Pass	33420	Pass
33421	Pass	33422	Pass	33423	Pass	33424	Pass
33425	Pass	33426	Pass	33427	Pass	33428	Pass
33429	Pass	33430	Pass	33431	Pass	33432	Pass
33433	Pass	33434	Pass	33435	Pass	33436	Pass
33437	Pass	33438	Pass	33439	Pass	33440	Pass
33441	Pass	33442	Pass	33443	Pass	33444	Pass
33445	Pass	33446	Pass	33447	Pass	33448	Pass
33449	Pass	33450	Pass	33451	Pass	33452	Pass
33453	Pass	33454	Pass	33455	Pass	33456	Pass
33457	Pass	33458	Pass	33459	Pass	33460	Pass
33461	Pass	33462	Pass	33463	Pass	33464	Pass
33465	Pass	33466	Pass	33467	Pass	33468	Pass
33469	Pass	33470	Pass	33471	Pass	33472	Pass
33473	Pass	33474	Pass	33475	Pass	33476	Pass
33477	Pass	33478	Pass	33479	Pass	33480	Pass
33481	Pass	33482	Pass	33483	Pass	33484	Pass
33485	Pass	33486	Pass	33487	Pass	33488	Pass
33489	Pass	33490	Pass	33491	Pass	33492	Pass
33493	Pass	33494	Pass	33495	Pass	33496	Pass
33497	Pass	33498	Pass	33499	Pass	33500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory