

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/137/25	Model No.: KFARQ-4-90%	Date: 01-08-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 137/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 13601 To 13700 And 13605A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 13605A and removed from the Lot/Batch							
13601	Pass	13602	Pass	13603	Pass	13604	Pass
13605	Pass	13606	Pass	13607	Pass	13608	Pass
13609	Pass	13610	Pass	13611	Pass	13612	Pass
13613	Pass	13614	Pass	13615	Pass	13616	Pass
13617	Pass	13618	Pass	13619	Pass	13620	Pass
13621	Pass	13622	Pass	13623	Pass	13624	Pass
13625	Pass	13626	Pass	13627	Pass	13628	Pass
13629	Pass	13630	Pass	13631	Pass	13632	Pass
13633	Pass	13634	Pass	13635	Pass	13636	Pass
13637	Pass	13638	Pass	13639	Pass	13640	Pass
13641	Pass	13642	Pass	13643	Pass	13644	Pass
13645	Pass	13646	Pass	13647	Pass	13648	Pass
13649	Pass	13650	Pass	13651	Pass	13652	Pass
13653	Pass	13654	Pass	13655	Pass	13656	Pass
13657	Pass	13658	Pass	13659	Pass	13660	Pass
13661	Pass	13662	Pass	13663	Pass	13664	Pass
13665	Pass	13666	Pass	13667	Pass	13668	Pass
13669	Pass	13670	Pass	13671	Pass	13672	Pass
13673	Pass	13674	Pass	13675	Pass	13676	Pass
13677	Pass	13678	Pass	13679	Pass	13680	Pass
13681	Pass	13682	Pass	13683	Pass	13684	Pass
13685	Pass	13686	Pass	13687	Pass	13688	Pass
13689	Pass	13690	Pass	13691	Pass	13692	Pass
13693	Pass	13694	Pass	13695	Pass	13696	Pass
13697	Pass	13698	Pass	13699	Pass	13700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory