

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/098/25	Model No.: KFARQ-2-90%	Date: 07-12-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 098/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 09701 To 9800 And 9705A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 9705A and removed from the Lot/Batch							
9701	Pass	9702	Pass	9703	Pass	9704	Pass
9705	Pass	9706	Pass	9707	Pass	9708	Pass
9709	Pass	9710	Pass	9711	Pass	9712	Pass
9713	Pass	9714	Pass	9715	Pass	9716	Pass
9717	Pass	9718	Pass	9719	Pass	9720	Pass
9721	Pass	9722	Pass	9723	Pass	9724	Pass
9725	Pass	9726	Pass	9727	Pass	9728	Pass
9729	Pass	9730	Pass	9731	Pass	9732	Pass
9733	Pass	9734	Pass	9735	Pass	9736	Pass
9737	Pass	9738	Pass	9739	Pass	9740	Pass
9741	Pass	9742	Pass	9743	Pass	9744	Pass
9745	Pass	9746	Pass	9747	Pass	9748	Pass
9749	Pass	9750	Pass	9751	Pass	9752	Pass
9753	Pass	9754	Pass	9755	Pass	9756	Pass
9757	Pass	9758	Pass	9759	Pass	9760	Pass
9761	Pass	9762	Pass	9763	Pass	9764	Pass
9765	Pass	9766	Pass	9767	Pass	9768	Pass
9769	Pass	9770	Pass	9771	Pass	9772	Pass
9773	Pass	9774	Pass	9775	Pass	9776	Pass
9777	Pass	9778	Pass	9779	Pass	9780	Pass
9781	Pass	9782	Pass	9783	Pass	9784	Pass
9785	Pass	9786	Pass	9787	Pass	9788	Pass
9789	Pass	9790	Pass	9791	Pass	9792	Pass
9793	Pass	9794	Pass	9795	Pass	9796	Pass
9797	Pass	9798	Pass	9799	Pass	9800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 SIHOR
 (GUJARAT)

Authorized Signatory