

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/138/25	Model No.: KFARQ-4-90%	Date: 09-08-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 138/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 13701 To 13800 And 13705A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 13705A and removed from the Lot/Batch							
13701	Pass	13702	Pass	13703	Pass	13704	Pass
13705	Pass	13706	Pass	13707	Pass	13708	Pass
13709	Pass	13710	Pass	13711	Pass	13712	Pass
13713	Pass	13714	Pass	13715	Pass	13716	Pass
13717	Pass	13718	Pass	13719	Pass	13720	Pass
13721	Pass	13722	Pass	13723	Pass	13724	Pass
13725	Pass	13726	Pass	13727	Pass	13728	Pass
13729	Pass	13730	Pass	13731	Pass	13732	Pass
13733	Pass	13734	Pass	13735	Pass	13736	Pass
13737	Pass	13738	Pass	13739	Pass	13740	Pass
13741	Pass	13742	Pass	13743	Pass	13744	Pass
13745	Pass	13746	Pass	13747	Pass	13748	Pass
13749	Pass	13750	Pass	13751	Pass	13752	Pass
13753	Pass	13754	Pass	13755	Pass	13756	Pass
13757	Pass	13758	Pass	13759	Pass	13760	Pass
13761	Pass	13762	Pass	13763	Pass	13764	Pass
13765	Pass	13766	Pass	13767	Pass	13768	Pass
13769	Pass	13770	Pass	13771	Pass	13772	Pass
13773	Pass	13774	Pass	13775	Pass	13776	Pass
13777	Pass	13778	Pass	13779	Pass	13780	Pass
13781	Pass	13782	Pass	13783	Pass	13784	Pass
13785	Pass	13786	Pass	13787	Pass	13788	Pass
13789	Pass	13790	Pass	13791	Pass	13792	Pass
13793	Pass	13794	Pass	13795	Pass	13796	Pass
13797	Pass	13798	Pass	13799	Pass	13800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory