

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/094/25	Model No.: KFARQ-2-90%	Date: 21-11-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 094/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 09301 To 9400 And 9305A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 9305A and removed from the Lot/Batch							
9301	Pass	9302	Pass	9303	Pass	9304	Pass
9305	Pass	9306	Pass	9307	Pass	9308	Pass
9309	Pass	9310	Pass	9311	Pass	9312	Pass
9313	Pass	9314	Pass	9315	Pass	9316	Pass
9317	Pass	9318	Pass	9319	Pass	9320	Pass
9321	Pass	9322	Pass	9323	Pass	9324	Pass
9325	Pass	9326	Pass	9327	Pass	9328	Pass
9329	Pass	9330	Pass	9331	Pass	9332	Pass
9333	Pass	9334	Pass	9335	Pass	9336	Pass
9337	Pass	9338	Pass	9339	Pass	9340	Pass
9341	Pass	9342	Pass	9343	Pass	9344	Pass
9345	Pass	9346	Pass	9347	Pass	9348	Pass
9349	Pass	9350	Pass	9351	Pass	9352	Pass
9353	Pass	9354	Pass	9355	Pass	9356	Pass
9357	Pass	9358	Pass	9359	Pass	9360	Pass
9361	Pass	9362	Pass	9363	Pass	9364	Pass
9365	Pass	9366	Pass	9367	Pass	9368	Pass
9369	Pass	9370	Pass	9371	Pass	9372	Pass
9373	Pass	9374	Pass	9375	Pass	9376	Pass
9377	Pass	9378	Pass	9379	Pass	9380	Pass
9381	Pass	9382	Pass	9383	Pass	9384	Pass
9385	Pass	9386	Pass	9387	Pass	9388	Pass
9389	Pass	9390	Pass	9391	Pass	9392	Pass
9393	Pass	9394	Pass	9395	Pass	9396	Pass
9397	Pass	9398	Pass	9399	Pass	9400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory