

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/334/25	Model No.: KFARQ-6-50%	Date: 23-11-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 334/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 33301 To 33400 And 33305A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 33305A and removed from the Lot/Batch							
33301	Pass	33302	Pass	33303	Pass	33304	Pass
33305	Pass	33306	Pass	33307	Pass	33308	Pass
33309	Pass	33310	Pass	33311	Pass	33312	Pass
33313	Pass	33314	Pass	33315	Pass	33316	Pass
33317	Pass	33318	Pass	33319	Pass	33320	Pass
33321	Pass	33322	Pass	33323	Pass	33324	Pass
33325	Pass	33326	Pass	33327	Pass	33328	Pass
33329	Pass	33330	Pass	33331	Pass	33332	Pass
33333	Pass	33334	Pass	33335	Pass	33336	Pass
33337	Pass	33338	Pass	33339	Pass	33340	Pass
33341	Pass	33342	Pass	33343	Pass	33344	Pass
33345	Pass	33346	Pass	33347	Pass	33348	Pass
33349	Pass	33350	Pass	33351	Pass	33352	Pass
33353	Pass	33354	Pass	33355	Pass	33356	Pass
33357	Pass	33358	Pass	33359	Pass	33360	Pass
33361	Pass	33362	Pass	33363	Pass	33364	Pass
33365	Pass	33366	Pass	33367	Pass	33368	Pass
33369	Pass	33370	Pass	33371	Pass	33372	Pass
33373	Pass	33374	Pass	33375	Pass	33376	Pass
33377	Pass	33378	Pass	33379	Pass	33380	Pass
33381	Pass	33382	Pass	33383	Pass	33384	Pass
33385	Pass	33386	Pass	33387	Pass	33388	Pass
33389	Pass	33390	Pass	33391	Pass	33392	Pass
33393	Pass	33394	Pass	33395	Pass	33396	Pass
33397	Pass	33398	Pass	33399	Pass	33400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory