

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/074/25	Model No.: KMCRQ-5	Date: 07-12-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 074/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 03651 To 3700	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03651 To 3700 and removed from the Lot/Batch							
3651	Pass	3652	Pass	3653	Pass	3654	Pass
3655	Pass	3656	Pass	3657	Pass	3658	Pass
3659	Pass	3660	Pass	3661	Pass	3662	Pass
3663	Pass	3664	Pass	3665	Pass	3666	Pass
3667	Pass	3668	Pass	3669	Pass	3670	Pass
3671	Pass	3672	Pass	3673	Pass	3674	Pass
3675	Pass	3676	Pass	3677	Pass	3678	Pass
3679	Pass	3680	Pass	3681	Pass	3682	Pass
3683	Pass	3684	Pass	3685	Pass	3686	Pass
3687	Pass	3688	Pass	3689	Pass	3690	Pass
3691	Pass	3692	Pass	3693	Pass	3694	Pass
3695	Pass	3696	Pass	3697	Pass	3698	Pass
3699	Pass	3700	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory