

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/136/25	Model No.: KFKHQ-6	Date: 20-12-2025
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 136/25	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 01351 To 1360 And 1355A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1355A and removed from the Lot/Batch							
1351	Pass	1352	Pass	1353	Pass	1354	Pass
1355	Pass	1356	Pass	1357	Pass	1358	Pass
1359	Pass	1360	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory