

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/081/26	Model No.: KFARQ-6-50%	Date: 24-02-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 081/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 08001 To 8100 And 8005A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 8005A and removed from the Lot/Batch							
8001	Pass	8002	Pass	8003	Pass	8004	Pass
8005	Pass	8006	Pass	8007	Pass	8008	Pass
8009	Pass	8010	Pass	8011	Pass	8012	Pass
8013	Pass	8014	Pass	8015	Pass	8016	Pass
8017	Pass	8018	Pass	8019	Pass	8020	Pass
8021	Pass	8022	Pass	8023	Pass	8024	Pass
8025	Pass	8026	Pass	8027	Pass	8028	Pass
8029	Pass	8030	Pass	8031	Pass	8032	Pass
8033	Pass	8034	Pass	8035	Pass	8036	Pass
8037	Pass	8038	Pass	8039	Pass	8040	Pass
8041	Pass	8042	Pass	8043	Pass	8044	Pass
8045	Pass	8046	Pass	8047	Pass	8048	Pass
8049	Pass	8050	Pass	8051	Pass	8052	Pass
8053	Pass	8054	Pass	8055	Pass	8056	Pass
8057	Pass	8058	Pass	8059	Pass	8060	Pass
8061	Pass	8062	Pass	8063	Pass	8064	Pass
8065	Pass	8066	Pass	8067	Pass	8068	Pass
8069	Pass	8070	Pass	8071	Pass	8072	Pass
8073	Pass	8074	Pass	8075	Pass	8076	Pass
8077	Pass	8078	Pass	8079	Pass	8080	Pass
8081	Pass	8082	Pass	8083	Pass	8084	Pass
8085	Pass	8086	Pass	8087	Pass	8088	Pass
8089	Pass	8090	Pass	8091	Pass	8092	Pass
8093	Pass	8094	Pass	8095	Pass	8096	Pass
8097	Pass	8098	Pass	8099	Pass	8100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory