

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/084/25	Model No.: KMCRQ-10	Date: 21-07-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 084/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00831 To 840	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00831 To 840 and removed from the Lot/Batch							
831	Pass	832	Pass	833	Pass	834	Pass
835	Pass	836	Pass	837	Pass	838	Pass
839	Pass	840	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory