



2245 A Street, Santa Maria CA 93455
Phone: (805) 739-2747 Fax: (805) 739-2751
www.wascoinc.com sales@wascoinc.com

Bill To:

FIRETRACE USA, LLC

EMAIL INVOICES TO:
fiaccounting@firetrace.com
8435 N. 90TH ST., STE. 2
SCOTTSDALE, AZ 85258
USA

PACKING LIST

Packing No: 00019361

Order #	Ship Date	Page
20053964	3/22/2022	1

Ship To:

FIRETRACE USA, LLC

8435 N. 90TH ST., STE. 2
SCOTTSDALE, AZ 85258
USA

Account No: 230017026

Certificate of Conformance				
Wasco Sales and Marketing certifies that all parts manufactured or supplied on subject purchase order are of good commercial quality and in accordance with applicable purchase order, drawings and specifications. Results of all chemical and/or physical tests, as well as all other evidence which shows acceptability of raw materials and assembly components, are on file and available for inspection at any reasonable time. Quality Representative Brent K. Baker				
CUSTOMER PO NUMBER	TERMS	SHIP VIA	F.O.B. POINT	
FT22-0096	NET 30 DAYS	FED-X PRIORITY OVERNIGHT	ORIGIN	
ORDERED BY	SALES REPRESENTATIVE	ORDER DATE	OUR ORDER #	CUSTOMER ID
CHRIS	IN-HOUSE (ALL)	2/3/2022	20053964	3478
C of C Required with Every Shipment				

LN	DL	SHIP DATE	ORDERED QUANTITY	SHIPPED QUANTITY	CAC	CARTONS	UNIT	PART IDENTIFIER	DESCRIPTION / COMMENTS	WEIGHT
01	01	3/22/2022	540.00	540.00	N		EA	3304	P6-X-0135J-0070J-DT36-B/3304 PRESSURE SWITCH 400005 PRESSURE SWITCH, M10X1,70PSI FALLING Ship with line 1.2 ... Lot: 50056151 Qty: 540	
01	02	3/22/2022	1.00	1.00	N		EA	CERTIFICATE OF CONFORMANCE	CERTIFICATE OF CONFORMANCE Ship with line 1.1	

3@150
1@90

CRCT04453
3-24-22 (RN)

CUST. PO TERMS: NET 30
C of C Required



QF27 Rev 008

9/1/2020



Certificate of Conformance::QF22

Customer PO Number

FT22-0096

Wasco SO Number

20053964-01-01

Quantity

540

Customer Part Number

400005

Wasco Part Number

P6-X-0135J-0070J-DT36-B/3304

Description

PRESSURE SWITCH

Wasco Sales and Marketing certifies that the parts listed above in the quantity shown have been manufactured using the processes and materials stated on the applicable drawings, specifications, and supplied requirements provided with the purchase order.

100% functionality testing, including continuity and short testing, has been conducted and conforms to the following specifications:

Activation Point: 70 PSIG SPDT DECREASING

Maximum Pressure: 270 PSIG

Proof Pressure: 270 PSIG

Amperage Rating: 3A 28 VDC

Brent K Baker, Quality Representative

Date

03/22/2022



2245 A Street, Santa Maria CA 93455
 Phone: (805) 739-2747 Fax: (805) 739-2751
 www.wascoinc.com sales@wascoinc.com

PACKING LIST

Packing No: 00019618

Order #	Ship Date	Page
20053964	4/20/2022	1

Bill To:

FIRETRACE USA, LLC

EMAIL INVOICES TO:
 ftaccounting@firetrace.com
 8435 N. 90TH ST., STE. 2
 SCOTTSDALE, AZ 85258
 USA

Ship To:

FIRETRACE USA, LLC

8435 N. 90TH ST., STE. 2
 SCOTTSDALE, AZ 85258
 USA

Account No: 230017026

Certificate of Conformance				
Wasco Sales and Marketing certifies that all parts manufactured or supplied on subject purchase order are of good commercial quality and in accordance with applicable purchase order, drawings and specifications. Results of all chemical and/or physical tests, as well as all other evidence which shows acceptability of raw materials and assembly components, are on file and available for inspection at any reasonable time. Quality Representative Brent K. Baker				
CUSTOMER PO NUMBER	TERMS	SHIP VIA	F.O.B. POINT	
FT22-0096	NET 30 DAYS	FED-X PRIORITY OVERNIGHT	ORIGIN	
ORDERED BY	SALES REPRESENTATIVE	ORDER DATE	OUR ORDER #	CUSTOMER ID
CHRIS	IN-HOUSE (ALL)	2/3/2022	20053964	3478
C of C Required with Every Shipment				

LN	DL	SHIP DATE	ORDERED QUANTITY	SHIPPED QUANTITY	C/C	CARTONS	UNIT	PART IDENTIFIER	DESCRIPTION / COMMENTS	WEIGHT
02	01	4/5/2022	459.00	459.00	N		EA	3304	P6-X-0135J-0070J-DT36-B/3304 PRESSURE SWITCH 400005 PRESSURE SWITCH, M10X1,70PSI FALLING Ship with line 2.2 ... Lot: 50056986 Qty: 459	
02	02	4/5/2022	1.00	1.00	N		EA	CERTIFICATE OF CONFORMANCE	CERTIFICATE OF CONFORMANCE Ship with line 2.1	

CRCTO 4589

4-21-22 (MAB)

CUST. PO TERMS: NET 30
 C of C Required



QF27 Rev 008

9/1/2020



Certificate of Conformance::QF22

Customer PO Number

FT22-0096

Wasco SO Number

20053964-02-01

Quantity

459

Customer Part Number

400005

Wasco Part Number

P6-X-0135J-0070J-DT36-B/3304

Description

PRESSURE SWITCH

Wasco Sales and Marketing certifies that the parts listed above in the quantity shown have been manufactured using the processes and materials stated on the applicable drawings, specifications, and supplied requirements provided with the purchase order.

100% functionality testing, including continuity and short testing, has been conducted and conforms to the following specifications:

Activation Point: 70 PSIG DECREASING

Maximum Pressure: 270 PSIG

Proof Pressure: 270 PSIG

Amperage Rating: 3A 28 VDC

Brent K Baker, Quality Representative

Date

04/20/2022