



Creating a safer world together

Certificate of Conformance

Batch	Order	Part Number	Description
405112 406112 408012 409012	FULFIL115448	204328 (Base PN 200005)	Firetrace Detection Tubing 4/6MM 328FT

The above material lot has been manufactured in compliance with the applicable manufacturing and quality requirements. The material has been visually inspected, stored, and handled in conformance with all requirements and is qualified for its intended use. Additional compliance information is listed below:

Standards:

- UL Certificate Number – 20140705 - S35465
- UL 521 - STANDARD FOR HEAT DETECTORS FOR FIRE PROTECTIVE SIGNALING SYSTEMS
- ISO 9001:2015 – Design, Manufacture and Support of Fire Suppression Systems

Test Results		
	Requirement	Result
Hydrostatic Burst	>1000 psi	Pass
Flame-Burst Duration	18 – 38 sec	Pass

Authorized Signature: _____

Date: _____

6/08/26

Firetrace International
8435 N 90th Street, Suite 2
Scottsdale, AZ. 85258 USA
(480) 607-1218
www.firetrace.com

FIRETRACE®

POWER TO INNOVATE. FLEXIBILITY TO ADAPT.

Detection Tubing Test Results

Document Number: QA-40006-C										Date:	11/9/2024		
Batch Information			Hydrostatic Burst Test - 10in Length						Flame Test - 5in Length				
Received Date	Batch/Extrusion #	Sample #	Tested Date	Initials	Burst Pressure > 1000 PSI	Pass	Fail	Tested Date	Initials	Burst Between 18 - 38 Seconds	Pass	Fail	Comments
10/30/2024	405112	1	11/9/2024	TS	1200	x		11/9/2024	TS	19	x		
10/30/2024	405112	2	11/9/2024	TS	1300	x		11/9/2024	TS	23	x		
10/30/2024	405112	3	11/9/2024	TS	1300	x		11/9/2024	TS	18	x		
10/30/2024	405112	4	11/9/2024	TS	1400	x		11/9/2024	TS	21	x		
10/30/2024	405112	5	11/9/2024	TS	1500	x		11/9/2024	TS	20	x		
10/30/2024	405112	6	11/9/2024	TS	1400	x		11/9/2024	TS	18	x		
10/30/2024	405112	7	11/9/2024	TS	1200	x		11/9/2024	TS	20	x		
10/30/2024	405112	8	11/9/2024	TS	1500	x		11/9/2024	TS	24	x		
10/30/2024	405112	9	11/9/2024	TS	1400	x		11/9/2024	TS	18	x		
10/30/2024	405112	10	11/9/2024	TS	1200	x		11/9/2024	TS	22	x		
10/30/2024	406112	1	11/9/2024	TS	1300	x		11/9/2024	TS	18	x		
10/30/2024	406112	2	11/9/2024	TS	1400	x		11/9/2024	TS	18	x		
10/30/2024	406112	3	11/9/2024	TS	1200	x		11/9/2024	TS	24	x		
10/30/2024	406112	4	11/9/2024	TS	1500	x		11/9/2024	TS	20	x		
10/30/2024	406112	5	11/9/2024	TS	1300	x		11/9/2024	TS	20	x		
10/30/2024	406112	6	11/9/2024	TS	1200	x		11/9/2024	TS	19	x		
10/30/2024	406112	7	11/9/2024	TS	1200	x		11/9/2024	TS	23	x		
10/30/2024	406112	8	11/9/2024	TS	1400	x		11/9/2024	TS	20	x		
10/30/2024	406112	9	11/9/2024	TS	1300	x		11/9/2024	TS	19	x		
10/30/2024	406112	10	11/9/2024	TS	1200	x		11/9/2024	TS	19	x		

* Please reference WI-50117, UL Incoming Test Procedure for Fire Detection Tubing, on how to perform the tests.

POWER TO INNOVATE. FLEXIBILITY TO ADAPT.

Document Number: QA-40006-C

- Please reference WI-50117, UL Incoming Test Procedure for Fire Detection Tubing, on how to perform the tests.

POWER TO INNOVATE. FLEXIBILITY TO ADAPT.

Document Number: QA-40076-C

• Please reference WI-S0117, UL Incoming Test Procedure for Fire Detection Tubing, on how to perform the tests.