

HELIUM LEAK DETECTION TEST

TC No.: HLD/KF/LI/HQ9/005/25

Model No.: KFLIHQ-9

Date: 28-06-2025

Type and Capacity of Extinguisher : KFLIHQ-9-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 9 Ltr.

Batch Number : KFLIHQ9 005/25

Batch Quantity : 10 Nos.

Serial Numbers : 00041 To 50

Month of Manufacturing : Jun/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
41	Pass	42	Pass	43	Pass	44	Pass
45	Pass	46	Pass	47	Pass	48	Pass
49	Pass	50	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**