

TEST CERTIFICATE

Product Details
Customer Name: Kanex Fire Solutions Ltd.

Product Description	2 Zone Smart Intelligent Panel	Model No:	SI-FS-2Z
Manufacturer	ASES Security Pvt. Ltd.	P.O. No	PO#18643-0
Address	A-2/69, Site - IV Sahibabad Indl. Area GZB, UP 201010	P.O. Date	14-Oct-25
		Invoice No.	ASPL2526UP3450
		Quantity	100 Nos.
		Date of Invoice	17-Oct-25
Phone No.	0120-4152341	Serial no.	5989-6088
Contact No.	Mr. Ajay Narkhede	Place of Manufacture	Sahibabad

Routine Testing Details:-

S.No.	Test Feature	Feature Standard	Observation
01	Cabinet	CRCA Sheet 18#AWG	OK
02	Paint	Marble White	OK
04	Fuse Rating	2 A / 250Vac	OK
08	Hooter Output	24Vdc / 2 A (max)	OK
09	Display Unit	16×2 Characters	OK
10	EOL	4K7	OK
13	AC Power	220Vac, 50Hz ± 10%	OK
14	Standby	24Vdc	OK
15	Operating Temperature	0°C to 55°C	OK
16	Operating Humidity	95% (non-condensing)	OK
17	Normal Loop Voltage	23Vdc to 24Vdc	OK
22	Fire Contact1 (C,NO,NC)	240Vac/24Vdc@ 7 A	OK
23	Fault Contact (C,NO,NC)	240Vac/24Vdc@ 7 A	OK

This is certify that **2 Zone Smart Intelligent Panel (SI-FS-2Z)** supplied as per details has been manufactured by ASES Security Private Limited tested as per the provision laid down in **IS 2189-1988** and the Electronics Regional Test Laboratory (**ERTL**).

Issue Date: - 05-11-25

Quality Assurance for ASES Security



TEST CERTIFICATE

Product Details:
Customer Name: Kanex Fire Solutions Ltd.

Product Description	Sounder With Strobe	Model No:	H-ABS-5
Manufacturer	ASES Security Pvt. Ltd	P.O. No	PO#18643-0
Address	A-2/69, Site - IV Sahibabad Indl. Area GZB, UP 201010	P.O.Date	14-Oct-25
		Invoice No.	ASPL2526UP3450
		Quantity	50 Nos.
Phone No.	0120-4152341	Place of Manufacture	Sahibabad
Contact Person	Mr. Ajay Narkhede	Date of Invoice	17-Oct-25

Routine Testing Details

S.No.	Test Feature	Feature Standard	Observation
01	Cabinet	ABS Plastic	OK
02	Paint	PO Red	OK
03	Operating Voltage	24V _{dc}	OK
04	Current consumption	100-120 mA / 24V _{dc}	OK
05	Sound Output	85-95 db	OK
06	Tone Type	Sweep Siren/Fourtllets/Ambulance/Fire Tone	OK
07	Operating temp.	32° TO 120° Fahrenheit	OK

This is certify that **Sounder With Strobe (H-ABS-5)** supplied as per details has been manufactured by **ASES Security Pvt. Ltd.** Tested as per the provision laid down in **IS 2189-1988** and the Electronics Regional Test Laboratory (**ERTL**).

Issue Date: - 05-11-25

Quality Assurance for ASES Security

