


DOC NUMBER		DESCRIPTION			
QD006		2.2 Test report			
INDEX	MODIFICATION (BRIEF DESCRIPTION)		DATE OF CHANGE		CHANGED BY (INITIALS)
-	creation		27/06/18		CM

Certificate of Compliance EN 10204-2.2			
Supplier: Fire Automatique Innovations S.a.r.l			
Customer : Kanex Fire Solutions Limited			
Order no.: PO#17891		Order confirmation:	
Delivery note : 2025-20806		2025-40529	
Description	Article no.:	Customers reference:	Quantity
End of Line Adapter	V1023011	F104004	2687
Perfomed tests			Results
Function test : 18bar -> ok			ok
Tightness : Helium leakage test : 18 Bar < 1 x 10⁻⁵ mbar * l / sec (100 % Helium)			ok

Date: 11.10.2025	Name: Th.Agethen	Signature: 
-------------------------	-------------------------	--