

Kanex Fire Solutions Ltd.

(Formerly known as Kanadia Fyr Fyter Pvt. Ltd.)

Plot No. 7-8, Paras Industrial Estate, Nr. Garibsha Pir,
Sihor- 364 240, Dist. Bhavnagar (Guj.) ☎ +91 85919 97014

✉ tc.kanexfire@kanexfire.com 🌐 www.kanexfire.com

CIN - U24111GJ1986PLC008699 MSME NO. UDYAM-GJ-05-0000619

**MATERIAL TEST CERTIFICATE ACCORDING TO EN 10204 3.1**

REPORT NO.: KF/MTC/2025-26/224

REPORT DATE :- 12.12.2025

ITEM DESCRIPTION	PART NO.	MODEL NO.	BATCH NO.	QTY
KANEX DLP VALVE	DLPVLV-006-F401003	KATS/K10119	A02/11/25	568 NOS.

PARAMETERS	SPECIFICATIONS	OBSERVATIONS
BODY	BRASS BS249/IS319 WITH CROME PLATTING DIA 38.5 MM, THREADS:M30X1.5P	PASSES
NO. OF PORTS	5 NOS.	PASSES
PRESSURE GUAGE PORT	M10X1 MM	PASSES
CONNECTOR PORT	M10X1 MM	PASSES
INLET/OUTLET PORT	1/8" BSP	PASSES
BLANK	M10X1 MM	PASSES
SAFETY RELEASE VALVE	BRASS, 304/304L SPRING, M11X1 MM	PASSES
WEIGHT	435 TO 445 GM.	PASSES
O RINGS & SEALS	NBR MATERIAL	PASSES
PRESSURE TEST	SERVICE PRESSURE @ 15 BAR	NO LEAKAGE OBSERVED
	HYDRO TEST @ 35 BAR	NO LEAKAGE OBSERVED
	BURST TEST @ 140 BAR	NO BURST OCCURED
TEMPERATURE TEST	OPERATIONAL TEMPERATURE @ 27±5 °C	PASSES
	HIGH TEMPERATURE @ 80 °C	PASSES
LEAKAGE TEST	LOW PRESSURE @ 0-8 BAR @ 27±5 °C	NO LEAKAGE OBSERVED
	HIGH PRESSURE @ 40 BAR @ 27±5 °C	NO LEAKAGE OBSERVED

REMARKS: DIMENSIONS AND THREADS CHECKED WITH APPROPRIATE GUAGES & FOUND SATISFACTORY.**FOR KANAX FIRE SOLUTIONS LTD.****AUTHORIZED QC SIGNATURE**