


DOC NUMBER		DESCRIPTION			
QDoo6		2.2 Test report			
INDEX	MODIFICATION (BRIEF DESCRIPTION)		DATE OF CHANGE	CHANGED BY (INITIALS)	
-	creation		27/06/18	CM	

Certificate of Compliance EN 10204-2.2			
Supplier: Fire Automatique Innovations S.a.r.l			
Customer : Kanex			
Order no.: PO#16544		Order confirmation: 2025-40504	
Delivery note : 2024-20637			
Description	Article no.:	Customers reference:	Quantity
Sensor Tube	C0410001	Fire Detection Tube black	200
Manufacturing date of tube			January 2025
Function Test (Witnessed by UL)			Ok / 25.02.2025
Perfomed tests			Results
Visual Check if marking is in accordance with drawing and UL specification			Ok
Dimension Check Ø 4 internal layer and Ø6 external layer			Ok
We confirm that the above product is compliant with the ordered goods			

Revisions:

Attachments

- Explanation of of decoding the production date
- Extraction of UL Test Report

Date: 12.05.2025	Name: Th.Agethen	Signature: 
-------------------------	-------------------------	---

Attachments :