

QMF01	Declaration of Conformity DoC	    Assessed to ISO 9001 Cert/LPCB ref No 085 Cert No FM 59294
Doc Page No: 1 of 1		
Revision: 3		
Issue Date: 22/08/2023		
Authorised By: T.Swadzba		

Bailey & Mackey Ltd Pressure Switch, Pressure Gauge and Pressure Transducer Manufacture Baltimore Road, Birmingham, B42 1DE Tel: 0121 357 5351 Fax: 0121 357 8319 E-mail: enquiries@baileymackey.com Registered in England No. 2140400
--

Declaration of Conformance

Customer:

KANEX FIRE SOLUTIONS LIM
 PLOT NO 7 PARAS INDUSTRIAL ESTATE
 NEAR GARIBSHA PIR DARGAH
 SIHOR 364240
 GUJARAT
 INDIA

JOB No: 00E8852 _____
 ENTERED: 05/09/25 _____
 YOUR ORDER No: PO#18131 _____

SPEC: AS DESCRIPTION _____
 QTY: 2000 _____

SERIAL No: 25E8852 0001 to 25E8852 2000 inclusive.

DESCRIPTION	TYPE 12 P. SWITCH, RANGE 5/35 bar. BRASS BASE Be. Cu. DIAPHRAGM, EPDM SEAL CONNECTION M10x1 C/W Z080E SINTERED FILTER IN PRESSURE PASSAGE TO DRG K601P SPDT MICRO SWITCH RATED 5A 250V 50HZ C/W 0.5M 4 CORE CABLE BROWN/ BLACK/ GREY/ EARTH FITTED WITH HEX GRUB SCREW. INTERNAL ADJUSTER SET AT 5 BAR FALLING MANUFACTURED IN ACCORDANCE TO S.E.P. REF PED – 2014/68/EC CE MARKED IN ACCORDANCE WITH THE LOW VOLTAGE DIRECTIVE 2014/35/EU
--	--

CERTIFIED THAT THE WHOLE OF THE SUPPLIES DETAILED HEREON HAVE BEEN INSPECTED,
 TESTED AND UNLESS OTHERWISE STATED CONFORM IN ALL RESPECTS WITH DETAILS OF THE
 CONTRACT OR ORDER AS DETAILED HEREWITH.

ALL TEST EQUIPMENT USED IN CONNECTION WITH THIS ORDER IS CERTIFIED TRACEABLE TO
 NATIONAL STANDARDS IN ACCORDANCE WITH REQUIREMENTS BS EN ISO 9001:2015

SIGNED: P Bolstridge _____
 POSITION: Q/A Department _____
 DATE: 06/11/25 _____