



TEST CERTIFICATE

Product Details
Customer Name: Kanex Fire Solutions Ltd.

Product Description	4 Zone Smart Intelligent Panel	Model No:	SI-FS-4Z
Manufacturer	ASES Security Pvt. Ltd.	P.O. No	PO#14799-0
Address	A-2/69, Site - IV Sahibabad Indl. Area GZB, UP 201010	P.O. Date	08-Jan-25
		Invoice No.	ASPL2425UP4996
		Quantity	50Nos.
		Date of Invoice	15-Jan-25
Phone No.	0120-4152341	Serial no.	5738-5787
Contact No.	Mr. Ajay V	Place of Manufacture	Sahibabad

Routine Testing Details:-

S.No.	Test Feature	Feature Standard	Observation
01	Cabinet	CRCA Sheet 18#AWG	OK
02	Paint	Marble White	OK
04	Fuse Rating	2 A / 250Vac	OK
08	Hooter Output	24Vdc / 2 A (max)	OK
09	Display Unit	16×2 Characters	OK
10	EOL	4K7	OK
13	AC Power	220Vac, 50Hz ± 10%	OK
14	Standby	24Vdc	OK
15	Operating Temperature	0°C to 55°C	OK
16	Operating Humidity	95% (non-condensing)	OK
17	Normal Loop Voltage	23Vdc to 24Vdc	OK
22	Fire Contact1 (C,NO,NC)	240Vac/24Vdc@ 7 A	OK
23	Fault Contact (C,NO,NC)	240Vac/24Vdc@ 7 A	OK

This is certify that **4 Zone Smart Intelligent Panel (SI-FS-4Z)** supplied as per details has been manufactured by ASES Security Private Limited tested as per the provision laid down in **IS 2189-1988** and the Electronics Regional Test Laboratory (ERTL).

Issue Date: - 15-Jan-25

Quality Assurance for ASES Security Pvt Ltd

