

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A2/A50/RQ/016/26      | Model No.: KFARQ-2-50%                                          | Date: 07-03-2026 |
| Type and Capacity of Extinguisher | : KFARQ-2-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg. |                  |
| Batch Number                      | : KFARQ50%2 016/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 01501 To 1600 And 1505A                                       |                  |
| Month of Manufacturing            | : Mar/26                                                        |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 1505A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1501                                                         | Pass   | 1502     | Pass   | 1503     | Pass   | 1504     | Pass   |
| 1505                                                         | Pass   | 1506     | Pass   | 1507     | Pass   | 1508     | Pass   |
| 1509                                                         | Pass   | 1510     | Pass   | 1511     | Pass   | 1512     | Pass   |
| 1513                                                         | Pass   | 1514     | Pass   | 1515     | Pass   | 1516     | Pass   |
| 1517                                                         | Pass   | 1518     | Pass   | 1519     | Pass   | 1520     | Pass   |
| 1521                                                         | Pass   | 1522     | Pass   | 1523     | Pass   | 1524     | Pass   |
| 1525                                                         | Pass   | 1526     | Pass   | 1527     | Pass   | 1528     | Pass   |
| 1529                                                         | Pass   | 1530     | Pass   | 1531     | Pass   | 1532     | Pass   |
| 1533                                                         | Pass   | 1534     | Pass   | 1535     | Pass   | 1536     | Pass   |
| 1537                                                         | Pass   | 1538     | Pass   | 1539     | Pass   | 1540     | Pass   |
| 1541                                                         | Pass   | 1542     | Pass   | 1543     | Pass   | 1544     | Pass   |
| 1545                                                         | Pass   | 1546     | Pass   | 1547     | Pass   | 1548     | Pass   |
| 1549                                                         | Pass   | 1550     | Pass   | 1551     | Pass   | 1552     | Pass   |
| 1553                                                         | Pass   | 1554     | Pass   | 1555     | Pass   | 1556     | Pass   |
| 1557                                                         | Pass   | 1558     | Pass   | 1559     | Pass   | 1560     | Pass   |
| 1561                                                         | Pass   | 1562     | Pass   | 1563     | Pass   | 1564     | Pass   |
| 1565                                                         | Pass   | 1566     | Pass   | 1567     | Pass   | 1568     | Pass   |
| 1569                                                         | Pass   | 1570     | Pass   | 1571     | Pass   | 1572     | Pass   |
| 1573                                                         | Pass   | 1574     | Pass   | 1575     | Pass   | 1576     | Pass   |
| 1577                                                         | Pass   | 1578     | Pass   | 1579     | Pass   | 1580     | Pass   |
| 1581                                                         | Pass   | 1582     | Pass   | 1583     | Pass   | 1584     | Pass   |
| 1585                                                         | Pass   | 1586     | Pass   | 1587     | Pass   | 1588     | Pass   |
| 1589                                                         | Pass   | 1590     | Pass   | 1591     | Pass   | 1592     | Pass   |
| 1593                                                         | Pass   | 1594     | Pass   | 1595     | Pass   | 1596     | Pass   |
| 1597                                                         | Pass   | 1598     | Pass   | 1599     | Pass   | 1600     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**