

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/203/25	Model No.: KFARQ-4-90%	Date: 25-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 203/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 20201 To 20300 And 20205A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20205A and removed from the Lot/Batch							
20201	Pass	20202	Pass	20203	Pass	20204	Pass
20205	Pass	20206	Pass	20207	Pass	20208	Pass
20209	Pass	20210	Pass	20211	Pass	20212	Pass
20213	Pass	20214	Pass	20215	Pass	20216	Pass
20217	Pass	20218	Pass	20219	Pass	20220	Pass
20221	Pass	20222	Pass	20223	Pass	20224	Pass
20225	Pass	20226	Pass	20227	Pass	20228	Pass
20229	Pass	20230	Pass	20231	Pass	20232	Pass
20233	Pass	20234	Pass	20235	Pass	20236	Pass
20237	Pass	20238	Pass	20239	Pass	20240	Pass
20241	Pass	20242	Pass	20243	Pass	20244	Pass
20245	Pass	20246	Pass	20247	Pass	20248	Pass
20249	Pass	20250	Pass	20251	Pass	20252	Pass
20253	Pass	20254	Pass	20255	Pass	20256	Pass
20257	Pass	20258	Pass	20259	Pass	20260	Pass
20261	Pass	20262	Pass	20263	Pass	20264	Pass
20265	Pass	20266	Pass	20267	Pass	20268	Pass
20269	Pass	20270	Pass	20271	Pass	20272	Pass
20273	Pass	20274	Pass	20275	Pass	20276	Pass
20277	Pass	20278	Pass	20279	Pass	20280	Pass
20281	Pass	20282	Pass	20283	Pass	20284	Pass
20285	Pass	20286	Pass	20287	Pass	20288	Pass
20289	Pass	20290	Pass	20291	Pass	20292	Pass
20293	Pass	20294	Pass	20295	Pass	20296	Pass
20297	Pass	20298	Pass	20299	Pass	20300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory