

# HYDRO PRESSURE TEST

|                                   |                                                               |                  |
|-----------------------------------|---------------------------------------------------------------|------------------|
| TC No.: HPT/A9/K/HQ/047/25        | Model No.: KFKHQ-9                                            | Date: 13-11-2025 |
| Type and Capacity of Extinguisher | : KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr. |                  |
| Batch Number                      | : KFKHQ9 047/25                                               |                  |
| Batch Quantity                    | : 10.00 Nos.                                                  |                  |
| Serial Numbers                    | : 00461 To 470                                                |                  |
| Month of Manufacturing            | : Nov/25                                                      |                  |

| Sr. Nos.                                                            | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 00461 To 470 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 461                                                                 | Pass   | 462      | Pass   | 463      | Pass   | 464      | Pass   |
| 465                                                                 | Pass   | 466      | Pass   | 467      | Pass   | 468      | Pass   |
| 469                                                                 | Pass   | 470      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**