

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/022/26	Model No.: KMCRQ-5	Date: 07-03-2026
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 022/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01051 To 1100	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01051 To 1100 and removed from the Lot/Batch							
1051	Pass	1052	Pass	1053	Pass	1054	Pass
1055	Pass	1056	Pass	1057	Pass	1058	Pass
1059	Pass	1060	Pass	1061	Pass	1062	Pass
1063	Pass	1064	Pass	1065	Pass	1066	Pass
1067	Pass	1068	Pass	1069	Pass	1070	Pass
1071	Pass	1072	Pass	1073	Pass	1074	Pass
1075	Pass	1076	Pass	1077	Pass	1078	Pass
1079	Pass	1080	Pass	1081	Pass	1082	Pass
1083	Pass	1084	Pass	1085	Pass	1086	Pass
1087	Pass	1088	Pass	1089	Pass	1090	Pass
1091	Pass	1092	Pass	1093	Pass	1094	Pass
1095	Pass	1096	Pass	1097	Pass	1098	Pass
1099	Pass	1100	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory