

# HYDRO PRESSURE TEST

|                                   |                                                                            |                  |
|-----------------------------------|----------------------------------------------------------------------------|------------------|
| TC No.: HPT/MOD5/CA/RQ/021/26     | Model No.: KMCRQ-5                                                         | Date: 24-02-2026 |
| Type and Capacity of Extinguisher | : KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg. |                  |
| Batch Number                      | : KMCRQ5 021/26                                                            |                  |
| Batch Quantity                    | : 50.00 Nos.                                                               |                  |
| Serial Numbers                    | : 01001 To 1050                                                            |                  |
| Month of Manufacturing            | : Feb/26                                                                   |                  |

| Sr. Nos.                                                             | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|----------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 01001 To 1050 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1001                                                                 | Pass   | 1002     | Pass   | 1003     | Pass   | 1004     | Pass   |
| 1005                                                                 | Pass   | 1006     | Pass   | 1007     | Pass   | 1008     | Pass   |
| 1009                                                                 | Pass   | 1010     | Pass   | 1011     | Pass   | 1012     | Pass   |
| 1013                                                                 | Pass   | 1014     | Pass   | 1015     | Pass   | 1016     | Pass   |
| 1017                                                                 | Pass   | 1018     | Pass   | 1019     | Pass   | 1020     | Pass   |
| 1021                                                                 | Pass   | 1022     | Pass   | 1023     | Pass   | 1024     | Pass   |
| 1025                                                                 | Pass   | 1026     | Pass   | 1027     | Pass   | 1028     | Pass   |
| 1029                                                                 | Pass   | 1030     | Pass   | 1031     | Pass   | 1032     | Pass   |
| 1033                                                                 | Pass   | 1034     | Pass   | 1035     | Pass   | 1036     | Pass   |
| 1037                                                                 | Pass   | 1038     | Pass   | 1039     | Pass   | 1040     | Pass   |
| 1041                                                                 | Pass   | 1042     | Pass   | 1043     | Pass   | 1044     | Pass   |
| 1045                                                                 | Pass   | 1046     | Pass   | 1047     | Pass   | 1048     | Pass   |
| 1049                                                                 | Pass   | 1050     | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**