


DOC NUMBER		DESCRIPTION			
QD006		2.2 Test report			
INDEX	MODIFICATION (BRIEF DESCRIPTION)		DATE OF CHANGE	CHANGED BY (INITIALS)	
-	creation		27/06/18	CM	

Certificate of Compliance EN 10204-2.2			
Supplier: Fire Automatique Innovations S.a.r.l			
Customer : Kanex Fire Solutions Limited			
Order no.: PO / 18835		Order confirmation: 2025-40541	
Delivery note : 2026-20911			
Description	Article no.:	Customers reference:	Quantity
Sensor Tube	C0410001	F103009	25000m (250 rolls)
Perfomed tests			Results
Visual Check if marking is in accordance with drawing and UL specification			ok
Dimension Check Dimension Check: Ø 4mm internal layer Ø6mm external layer 1mm (+0,1mm/-0,2mm) Wall Thickness Bending Radius: <25cm			ok
We confirm that the above product is compliant with the ordered goods			ok

Date: 01.01.2026	Name: Th.Agethen	Signature: 
-------------------------	-------------------------	--