

HYDRO PRESSURE TEST

TC No.: HPT/WM6/HQ/003/26	Model No.: KFWMSHQ-6	Date: 01-02-2026
Type and Capacity of Extinguisher	: KFWMSHQ-6-Water Mist Type Portable Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFWMSHQ6 003/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00021 To 30 And 25A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25A and removed from the Lot/Batch							
21	Pass	22	Pass	23	Pass	24	Pass
25	Pass	26	Pass	27	Pass	28	Pass
29	Pass	30	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory